

Kitemark™ Certificate

This is to certify that:

Jactone Products Ltd
Springvale Business Park
Springvale Avenue
Bilston
West Midlands
WV14 0QL
United Kingdom

Holds Certificate Number:

KM 57904

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2001-05-16

Latest Issue: 2024-04-29

Effective Date: 2024-04-29

Expiry Date: 2024-11-06

Page: 1 of 4



Kitemark™ Certificate

No. KM 57904

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
EGS6	6 litre, water based (FIREBLOCK LITHIUM), stored pressure. Fire rating: 8A	JT-6031-G, Revision 0 dated 2023-04-04	3947470
EGS9	9 litre, water based (FIREBLOCK LITHIUM), stored pressure. Fire rating: 13A	JT-6032-G, Revision 0 dated 2023-04-04	3947470

All the above products are certified to BS EN 3-7:2004+A1:2007

Suitability for li-ion fire types is outside the scope of this certification.

First Issued: 2001-05-16

Latest Issue: 2024-04-29

Effective Date: 2024-04-29

Expiry Date: 2024-11-06

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.