





## Kitemark™ Certificate

This is to certify that: **Jactone Products Limited** 

Springvale Business Park Springvale Avenue

Bilston WV14 0QL United Kingdom

Holds Certificate Number: KM 805775

In respect of:

**SANS 1910** Portable refillable fire extinguishers

The issues and right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Group South Africa (Pty) Ltd (the "Conditions). All defined terms in this certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

Theuns Kotze, Regional Director - META

First Issued: 2024-08-28 Effective Date: 2024-11-14 Latest Issue: 2024-11-14 Expiry Date: 2027-11-06

Page: 1 of 2



For and on behalf of BSI:

This certificate has been issued by and remains the property of BSI Group South Africa (Pty) Ltd, Park Lane West, 194 Bancor Avenue, Waterkloof Glen X2, Pretoria, 0181, South Africa and should be returned immediately upon request.

To check its validity telephone +27 (0)12 004 0279. An electronic certificate can be authenticated online.

## Kitemark™ Certificate

No. KM 805775

Model No	Description	GAD Drawing Reference, Revision & Date	Technical File Review
EGS9	9 litre water based (FIREBLOCK LITHIUM), stored pressure extinguisher. Temperature range: 5 °C to 60 °C Working pressure at 20 °C: 15 bar Fire rating: 13A	JT-6037-G, Revision 1 dated 2024-04-08	30115873

All the above products are certified to SANS 1910:2022

Suitability for li-ion fire types is outside the scope of this certification

First Issued: 2024-08-28 Effective Date: 2024-11-14 Latest Issue: 2024-11-14 Expiry Date: 2027-11-06

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Group South Africa (Pty) Ltd, Park Lane West, 194 Bancor Avenue, Waterkloof Glen X2, Pretoria, 0181, South Africa and should be returned immediately upon request. To check its validity telephone +27 (0)12 004 0279. An electronic certificate can be authenticated online.